

STIFFENER ANGLE
BY OTHERS. SIZE
RECOMMENDED ON
TABLE 4b OF
KINETICS "SITE
SPECIFIC FORCE
CLASS TABLES".

KHRC-A ADJUSTABLE
ANGLE STIFFENER
KIT BY KINETICS.

L3

L2

L1

CLEVIS HANGER
BY OTHERS.

COUPLING &
ANCHOR BY
OTHERS.

THREADED
HANGER
ROD BY
OTHERS.

KSWC CABLE
RESTRAINT
KIT SHOWN
BY KINETICS.

KCHB CLEVIS
HANGER BRACE
KIT SHOWN
BY
KINETICS.

IMPORTANT NOTES:

- 1.) THE VALUES OF L2 AND (L1+L3) MUST NOT EXCEED THE MAXIMUM UNSTIFFENED HANGER ROD LENGTH FROM TABLE 4b OF KINETICS "SITE SPECIFIC FORCE CLASS TABLES".
- 2.) A MINIMUM OF TWO (2) KHRC-A'S ARE REQUIRED PER HANGER ROD INSTALLATION.

THIS COMPONENT IS SUITABLE FOR SEISMIC APPLICATIONS SUBJECT TO THE QUALIFICATIONS INDICATED ON THIS DRAWING



TITLE
KHRC-A INSTALLATION
NON-ISOLATED HANGER

DATE
02/03/04

REVISED BY
TEF

DRAWING NO.
S-90.500-1B