



IMPORTANT NOTES:

- 1.) THE VALUES OF L2 AND (L1+L3) MUST NOT EXCEED THE MAXIMUM UNSTIFFENED HANGER ROD LENGTH.
- 2.) A MINIMUM OF TWO (2) KHRC-A'S ARE REQUIRED PER HANGER ROD INSTALLATION.

THIS COMPONENT IS SUITABLE FOR SEISMIC APPLICATIONS SUBJECT TO THE QUALIFICATIONS INDICATED ON THIS DRAWING

	KINETICS Noise Control	TITLE KHRC-A INSTALLATION NON-ISOLATED HANGER	DATE 7/20/2021	REVISED BY AVF	DRAWING NO. S-90.500-1B